

DISTRICT WATER TESTING LABORATORY, MANSA
Water Supply and Sanitation division no. 1 Complex, Jawaharke, Mansa, District Mansa
dwtlmsansa@gmail.com



TC-11388

TEST REPORT

Name & Address of Customer : SWEET BLOSSOMS SCHOOL SIRSA ROAD,SARDULGARH,DISTT.MANSA		Customer Reference No.	No : SBS 29-05-2026 Dated : 18/05/2026	
		Sample Submitted by	MR VIKAS KUMAR	
		Date of Sample Receipt	18/05/2026	
		Analysis Starting Date	18/05/2026	
		Analysis completion Date	19/05/2026	
Discipline :		Group: Water		
ULR No.:	TC113862600000244F	Sample Type :	Water	
Test Report No.:	DWTL/MNS/2627/00169	Date of Issue :	19/05/2026	
Registration no.:	DWTL/MNS/REG2627/00459	Condition of Sample :	Unsealed	
Collection Point:	Treatment Plant (RO/CWPP/ARP/HH Purifier)	Quantity/Type of Bottle:	1000 ml / Transparent Plastic Bottle	
Scheme/Source:	Not Mentioned(Not Mentioned)	Location/Depth :	S B S,SIRSA ROAD,SARDULGARH,DISTT.MANSA / NA	
Village :	Not Mentioned	Habitation :	Not Mentioned	
Block:	Not Mentioned	District :	Mansa	
Latitude :	Not Mentioned	Longitude:	Not Mentioned	

Sr. No	Parameter	Result	As per IS-10500:2012 (2nd Rev.)		Unit	Reference Method :
			Acceptable Limit	Permissible Limit		
1	pH	7.12@25°C	6.5-8.5	No Relaxation	--	IS 3025 (Part 11-2022) Electrometric Method
2	Colour	2	5	15	CU	IS 3025(Part 4-2021) Visual Comparison Method
3	Odour	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 5 – 2018) (Second Revision)
4	Taste	NT	Agreeable	Agreeable	--	IS 3025 (Part 8 – 2023)
5	TDS	138	500	2000	mg/l	IS 3025 (Part 16-2023) Gravimetric Method
6	Turbidity	BDL	1	5	NTU	IS 3025 (Part 10-2023) Nephelometric Method
7	T. Alkalinity(CaCO3)	38	200	600	mg/l	IS 3025 (Part 23-2023) Indicator Method
8	T. Hardness(CaCO3)	38	200	600	mg/l	IS 3025 (Part 21- 2009)(RA 2023) EDTA Method
9	Calcium(Ca)	8.81	75	200	mg/l	IS 3025 (Part 40-2024) EDTA Titrimetric Method
10	Magnesium(Mg)	3.88	30	100	mg/l	APHA (24th Ed.2023) Method: 3500-Mg+2 B By Calculation Method
11	Chloride(Cl)	45.98	250	1000	mg/l	IS 3025 (Part 32-1988) Argentometric Method

This Report is issued under the following terms & Condition :

1. The results apply to the sample as received only.
2. The sample will be destroyed after retention time unless otherwise specified specially.
3. This report is not to be reproduce wholly or in part and can't be used as evidence in court of law.
4. Abbreviation used (TDS = Total Dissolved Solids, mg/l = milligram per liter, BDL = Below detection limit, APHA = American Public Health Association, IS = Indian Standard, NT = Not Tested, NA = Not Applicable NTU = Nephelometric Turbidity Unit, RA = Reaffirmed, ND=Not Detected, T=Total)
5. * Value not available or test not performed for this parameter.
6. Temperature condition limit: 25±5°C and Humidity condition limit:50 ±20%

Reviewed and Approved By

Komal Sharma

Ms. Komal Sharma
Quality Manager
Authorized Signatory
For, District Water Testing Laboratory
Mansa

(Signature)
Principal
Sweet Blossoms School
Sardulgarh (Mansa)
Affiliated to C.B.S.E New Delhi
Aif No 1630825, School No 20800

----- End of the Test Report -----

DISTRICT WATER TESTING LABORATORY, MANSA

Water Supply and Sanitation division no. 1 Complex, Jawaharke, Mansa, District Mansa
dwtlmansa@gmail.com

To,

SWEET BLOSSOMS SCHOOL
SIRSA ROAD, SARDULGARH, DISTT. MANSA

No.: DWTL/MNS/2627/00169 Dated : 19/05/2026

Subject : Testing Reports of Water Samples.

Reference: Your Letter/SRF No. SBS 29-05-2026 Dated: 18/05/2026

As per above cited subject and reference, Please find enclosed here with the report of 1 Water sample/s received on dated 18/05/2026. It is request to fill the attached feedback form and send it back to District Water Testing Laboratory, Mansa

D/A : Test Report

Singh
Principal
Sweet Blossoms School
Sardulgarh (Mansa)
Affiliated to C.B.S.E New Delhi
Aff No 1630825, School No 20800

Komal Sharma
Authorized Signatory
For, District Water Testing Laboratory
Mansa